

School Board Members

Mary M. Benjamin
Betty T. Haney
Sherilyn H. Merritt
Barbara T. Pittman
Jerry W. Schnepf, Jr.



Superintendent
Dr. Kari Weston

Clerk of the Board
Bonnie L. Gholson

Dinwiddie County Public Schools
OFFICE OF THE SUPERINTENDENT

REQUEST FOR QUOTE
NAME: PARKING LOT IMPROVEMENTS
NUMBER: 20-022620
ADDENDUM #1

ISSUE DATE: 02/26/20

DUE DATE/TIME: 03/30/2020, 2:00 P.M.

The following are questions/clarifications we have received regarding this RFQ to date.

Issued by: Brenda Austin
Telephone: 804-469-4190
Fax: (24 Hours a day): 804-469-4197
Email: baustin@dcpsnet.org

What Brands and materials composition are you requiring?

Industry standards for parking lot sealer

Number of coats contractor is to provide for "sealer"?

One (1) coat

Timing Schedule - Time of year/day restrictions to allow for school in session.

Begin after 6/22/2020 – Finish before 8/14/2020

Are there any parking lines, crosswalks, stop bars, etc. that require thermoplastic paints?

No