

School Board Members

Mary M. Benjamin
Betty T. Haney
Sherilyn H. Merritt
Barbara T. Pittman
Jerry W. Schnepf, Jr.



Superintendent
Dr. Kari Weston

Clerk of the Board
Bonnie L. Gholson

Dinwiddie County Public Schools
OFFICE OF THE SUPERINTENDENT

INVITATION FOR BID
NAME: REHABILITATION OF SILICONE ROOFING SYSTEMS
NUMBER: IFB# 20-070720
ADDENDUM #2

ISSUE DATE: 07/07/20

DUE DATE/TIME: 07/21/2020, 3:00 P.M.

ADDENDUM DATE: 07/15/20

The following are questions/clarifications we have received regarding this IFB to date.

Issued by: Brenda Austin
Telephone: 804-469-4190
Fax: (24 Hours a day): 804-469-4197
Email: baustin@dcpsnet.org

Changes to Attachment B

The Base Bid should include the removal or replacement of any wet and/or deteriorated insulation as indicated in the Infrared Scan/Moisture Survey conducted by Wood PLC Engineering.

Bidder should indicate the additional cost per square foot for any removal or replacement of any wet and/or deteriorated insulation revealed during the roof rehabilitation.

Attachment B has been adjusted to include a combined cost of Project 1 and Project 2 bid together.

Granules

Granules must be used in the re-coat. See section 13.1.1.2 number 2.05 Granules on page 5 of the BASF Guide Specification for specifications regarding Granules.

Wood Environment and Infrastructure Solutions, Inc. IR Scan

The IR Scan showing Dinwiddie Junior High School – (Should read Dinwiddie Middle School) – Sections A-D & Q shows sections listed as “Wet Area”. See attached IR Scan with comments attached regarding each spot that was questioned for clarification. See note tabs on the drawings for clarification to questions raised at pre-bid meeting.

Is there a penalty if not completed by August 27, 2020?

In lieu of monetary damages, we would require the contractor to remove all equipment and materials off site and only return to the job site after school hours.

Note: A signed acknowledgment of this addendum must be attached to your bid. Signature on this addendum does not constitute signature on the original bid document. The original bid document must also be signed per bid instructions.

Name of Firm: _____

Signature: _____

Type/Print Name: _____

Title: _____

Date: _____